

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 109

Dated: 07/05/25

It is certified that an inspection team headed by Abhishek (AEN)

(Name of officers with designation) from CSD Digan Jodhpur PHED

inspected the Global Indian International School, Near Shikargarh Palace, Shri Yade Nagar, Nandra Kallan, Shikargarh, Jodhpur- 342015 (Name & Address of the school) on

(date of inspection) and on basis of Water Test Report (Attached) bearing no. dated

of office of the sup. chemist lab Jodhpur (PHED Lab) certified that the

Global Indian International School, Shikargarh, Jodhpur (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central / State / U. T. Govt.

This certificate is valid till 02/05/26

Signature with Seal: [Signature]

Name : Abhishek

Designation : Assistant Dy.

Name & Address of the Office / Department:

City Subdr. Digan Jodhpur

[Signature]
DIRECTOR
GLOBAL INDIAN INTERNATIONAL SCHOOL
JODHPUR

To

Global Indian International School

Near Shikargarh Palace, Shri Yade Nagar,

Nandra Kallan, Shikargarh, Jodhpur- 342015

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

सहायक अभियंता
उत्तम स्वा. अभि. निदेश
नगर उपायुक्त, जिला
जोधपुर (230001)

[Signature]
Principal
Global Indian International School
Shriyade Nagar, Near Shikargarh Palace,
NANDRA KALLA, JODHPUR



OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT,
REGIONAL LABORATORY-JODHPUR (RAJ.)

Email:- phedregionallabjodhpur@gmail.com

No. Lab/Tech/Chm./2025-2026/ 29

Date : 17-04-2025

TEST REPORT OF THE CHEMICAL EXAMINATION OF WATER

To,

Not for Legal Purpose

PRINCIPAL

GLOBAL INDIAN INTERNATIONAL SCHOOL

NEAR SHIKARGARH PLACE, SHIKARGARH

JODHPUR

SAMPLE WAS NOT COLLECTED
BY THE LABORATORY

District: JODHPUR

Reference: ADMIN/04

Dated: 07-04-2025

Sample Taker: Shubham

Date of Receipt	09-04-2025
Date of Collection	08-04-2025
Date of Examination	17-04-2025
Source Type	Tape Water
Source Location	NEAR SHIKARGARH PLACE, SHIKARGARH
City	JODHPUR
Lab Sample No.	PC-03

S. No.	Characteristics	Permissible Value as per BIS 10500/ 2012 Drinking Water Standards		Test Results
		Desirable Limit	Permissible Limit in absence of alternate Source	
1	pH @ 25 °C	6.5 to 8.5	No relaxation	7.40
2	Turbidity(NTU)	1	5	0.30
3	Colour	5	15	1.00
4	Odour	Agreeable	Agreeable	Agreeable
5	Temperature	----	----	-
6	Total Alkalinity (as CaCO ₃)	200	600	100
7	Total Hardness (as CaCO ₃)	200	600	112
8	Calcium (as Ca++)	75	200	27.20
9	Magnesium (as Mg++)	30	100	10.56
10	Chloride (as Cl-)	250	1000	44
11	Sulphate(as SO ₄)	200	400	26
12	Nitrates (as NO ₃ -)	45	No relaxation	2.00
13	Fluoride (as F-)	1	1.5	0.28
14	Total Dissolved Solids (TDS)	500	2000	260

Remark:-

No. Lab/Tech/Chm./2025-2026/

Copy to:

1. The Chief Chemist, Public Health Engineering Department-Rajasthan, Jaipur.

Signature
DIRECTOR
GLOBAL INDIAN INTERNATIONAL SCHOOL
JODHPUR

Date :

Signature
Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur

Signature
Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur

Signature
Principal
Global Indian International School
Sriyade Nagar, Shikargarh Patana,
JODHPUR