

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATENo. 187Dated: 25/05/26It is certified that an inspection team headed by Abhishek (AS)
(Name of officers with designation) from CSD PIGDP Jodhpur PHEDinspected the Global Indian International School, Siri Yade Nagar, Near Shikargarh Palace,
Nandra Kalla, Shikargarh, Jodhpur- 342015 (Name & Address of the school) on
25/05/26 (date of inspection) and on basis of Water TestReport (Attached) bearing no. 154 dated 20/05/26
of office of Eng. Chemist PHED JOD (PHED Lab) certified that theGlobal Indian International School, Shikargarh, Jodhpur (Name of school) has safe
drinking water facilities for the students and members of staff of the institution. School is
also maintains the hygienic sanitation condition in the school building & the campus as
per norms prescribed by the central / State / U. T. Govt.This certificate is valid till 24/04/27Signature with Seal: Name: AbhishekDesignation: Asst. Eng.

Name & Address of the Office / Department:

City Subdiv Jodhpur

सहायक अभियंता
जन स्वा. अमि. विभाग
नगर उपखण्ड डिवाइज
जोधपुर (342015)

To

Global Indian International School
Siriyaide Nagar, Near Shikargarh Palace,
Nandra Kalla, Shikargarh, Jodhpur- 342015
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT,
REGIONAL LABORATORY-JODHPUR (RAJ.)

Email:- phedregionallabjodhpur@gmail.com

No. Lab/Tech/Chm./2026-27/ 154

Date : 20-05-2026

TEST REPORT OF THE CHEMICAL EXAMINATION OF WATER

To,

PRINCIPAL
GLOBAL INDIAN INTERNATIONAL SCHOOL
Siriya Nagar Near Shikargarh Palac Nandra Kalla Shikargarh
JODHPUR

SAMPLE WAS NOT COLLECTED
BY THE LABORATORY

Reference: 9


Dated: 12.05.2026

Sample Taker: KAILASH SOLANKI

Date of Reciept	12.05.2026
Date of Collection	12.05.2026
Date of Examination	14.05.2026
Source Type	TAP WATER
Source Location	Not for Legal Purpose Siriya Nagar Near Shikargarh Palac Nandra Kalla Shikargarh
City	JODHPUR
Lab Sample No.	PC- 16

S. No.	Characteristics	Permissible Value as per BIS 10500/2012 Drinking Water Standards		Test Results
		Desirable Limit	Permissible Limit in absence of alternate Source	
1	pH @ 25 °C	6.5 to 8.5	No relaxation	6.80
2	Turbidity(NTU)	1	5	0.10
3	Colour	5	15	NIL
4	Odour	Agreeable	Agreeable	Agreeable
5	Temperature	----	----	-
6	Total Alkalinity (as CaCO ₃)	200	600	24
7	Total Hardness (as CaCO ₃)	200	600	60
8	Calcium (as Ca ⁺⁺)	75	200	12.80
9	Magnesium (as Mg ⁺⁺)	30	100	6.72
10	Chloride (as Cl ⁻)	250	1000	32
11	Sulphate(as SO ₄)	200	400	12
12	Nitrates (as NO ₃ ⁻)	45	No relaxation	1.26
13	Fluoride (as F ⁻)	1	1.5	0.05
14	Total Dissolved Solids (TDS)	500	2000	108

Remark:-


Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur

No. Lab/Tech/Chm./2026-27/

Date :

Copy to:

1. The Chief Chemist, Public Health Engineering Department-Rajasthan, Jaipur.

Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur